Montana Fish, Wildlife & Parks

January 6, 2014

STATE OF MONTANA
INVITATION FOR BID ADDENDUM
IFB NO. 140126
TO BE OPENED: ~~January 2, 2014~~ January 14, 2014
TITLE: Spring Meadow Comfort Station

ADDENDUM NO. 2

To All Bidders:

Attached are written questions received in response to this IFB. These questions, along with the State's response, become an official amendment to this IFB.

All other terms of the subject "Invitation for Bid" are to remain as previously stated.

Acknowledgment of Addendum:

The bidder for this solicitation must acknowledge receipt of this addendum. This page must be submitted at the time set for the bid opening or the bid may be disqualified from further consideration.

I acknowledge receipt of Addendum No. 2.

Signed: _____

Company Name: _____

Date: _____

Sincerely,

Kari Shinn
Purchasing Officer
PO Box 200701
Helena, MT 59620
406-495-3249

Question Number	Page Number	Section Number	Questions & Answers for IFB # 140126
1.	16	Q.1	Question: Is there a reason you specified steel windows? There are commercial-rated aluminum windows available. ***Answer: Yes, aluminum commercial-rated windows would be acceptable.***
2.	16	Q.1	Question: What is a "cleanout cover"? ***Answer: This is a carryover from a storm window specification and does not apply to this situation.***
3.	16	Q.2	Question: What is meant by "industrial" grade glazing? ***Answer: We simply want to convey that we need a commercial grade window that is well built and will stand up to the elements and the public uses that it is intended for.***
4.	16	Q.3	Question: Windows are specified to have a 2" setback, but the 4'x3' sliding window will requires a minimum depth of 5" in a steel window. With the setback, the window will stick out because the wall is only 4" deep. Can you please verify this is what you actually want? ***Answer: If the window thickness will not allow for the setback, then that provision would not apply to that particular window. The setback is intended to allow FWP staff to "board-up" the windows when the Park is closed to prevent vandalism.***
5.	16	R.	Question: Plumbing; are these fixtures to be installed in a future bid? There is no specification for piping, valves, water heaters, insulation and lot other items to provide a rough-in price for these fixtures. ***Answer: All of the plumbing in the chase will be installed under another contract. The vendor needs only to mount the fixtures (toilets, urinal, sinks, etc.) to the wall and extend the plumbing through to the chase. If piping is needed over and above what comes with the fixture, any pipe material that is commonly accepted as industry standard will suffice.***

Question Number	Page Number	Section Number	Questions & Answers for IFB # 140126
6.	16	R.	Question: What about all of the plumbing in the concrete slab? ***Answer: The subsurface connections and slab penetrations for water, sewer, electrical, and the concrete slab will all be done under a separate contract.***